

Grohe Shower Diverter Mixer models;

Lineare New  
Eurosmart New  
Bauedge  
Essence New  
Allure  
Grandera  
Concetto

*Pure Freude  
an Wasser*



Installation/Testing Instructions

## Technical Information

- Maximum hot water temperature – 70c (Nominal Temperature 60c).
- Maximum pressure – 500 kPa (Install pressure limiting valve to ensure max. 500 kPa).
- Minimum Pressure – 50 kPa.

## Static Pressure Testing Instruction

### WITH VALVE INSTALLED

- In closed position, increase water pressure to maximum 1600 kPa (Or 1500 kPa in accordance with AS/NZS 3500).
- Test for a minimum of 30 minutes, and a maximum of 60 minutes.
- Inspect product for any leaks or deformations (If cartridge leaks, replace full cartridge immediately and re-test for leaks).
- Reduce pressure down to 500 kPa.

### WITH VALVE BYPASSED OR REMOVED

- Follow standard process as outlined in accordance with AS/NZS 3500 series of standards.



**IMPORTANT NOTE – IF STATIC PRESSURE TESTING THE OUTLET PIPE TO THE SHOWER HEAD IS REQUIRED, MIXER MUST BE ISOLATED (in closed position) AND BYPASSED FOR THE DURATION OF THE TEST – failure to do so will void warranty.**



**Product must be installed in accordance with AS/NZS 3500 series of standards.**



**The hot water temperature must be controlled by a Watermark certified tempering valve, or other suitable certified thermostatic mixing valve.**

**Plumbers, please ensure a copy of the installation instruction is left with the end user for future reference.**

