

Grohe Shower Mixer models;
Lineare New
Eurosmart New
Bauedge
Essence New
Allure
Grandera
Concetto

*Pure Freude
an Wasser*



Installation/Testing Instructions

Technical Information

- Maximum hot water temperature – 70c (Nominal Temperature 60c).
- Maximum pressure – 500 kPa (Install pressure limiting valve to ensure max. 500 kPa).
- Minimum Pressure – 50 kPa.

Static Pressure Testing Instruction

WITH VALVE INSTALLED

- In closed position, increase water pressure to maximum 1600 kPa (Or 1500 kPa in accordance with AS/NZS 3500).
- Test for a minimum of 30 minutes, and a maximum of 60 minutes.
- Inspect product for any leaks or deformations (If cartridge leaks, replace full cartridge immediately and re-test for leaks).
- Reduce pressure down to 500 kPa.

WITH VALVE BYPASSED OR REMOVED

- Follow standard process as outlined in accordance with AS/NZS 3500 series of standards.



IMPORTANT NOTE – IF STATIC PRESSURE TESTING THE OUTLET PIPE TO THE SHOWER HEAD IS REQUIRED, MIXER MUST BE ISOLATED (in closed position) AND BYPASSED FOR THE DURATION OF THE TEST – failure to do so will void warranty.



Product must be installed in accordance with AS/NZS 3500 series of standards.



The hot water temperature must be controlled by a Watermark certified tempering valve, or other suitable certified thermostatic mixing valve.

Plumbers, please ensure a copy of the installation instruction is left with the end user for future reference.

