

EZ TRAP®

U.S. Patent Numbers 5,069,042 5,522,229

Model No.

83113

(EZT 113)


3/4" Standard Condensate Trap. No Brush

1" DROP

Kit Contents

- 3/4" Standard Trap (1)
- 3/4" Cross (1)
- 3/4" Tee (1)
- Red Caps (3)
- Yellow Cleaning Label (1)

Scan for more info



3 YEAR WARRANTY. The manufacturer disclaims all implied and express warranties, including the implied warranty of merchantability and the implied warranty of fitness for a particular purpose, except as follows: The EZ-Trap condensate trap or overflow switch purchased by you is unconditionally warranted to be free from defects in material and workmanship under normal use for a period of three (3) years from date of purchase, providing it is installed and operated strictly in accordance with manufacturer's installation instructions. If the product is found to be defective or otherwise fails in normal use, you may return it for replacement. All freight charges for the return of the product shall be borne by you. The manufacturer will pay outgoing freight charges for the replacement product. Defective products returned to the factory prepaid will be repaired or replaced free of charge. Replacement product will, to the extent such product is then available in manufacturer's inventory, be of similar type, color and kind. Manufacturer retains the right to substitute product if replacement product does not conform in terms of color, type and specifications to the original product, if no longer available. This warranty does not cover replacement labor or any cost, claim or incident to any defect nor does it cover freezing or any other consequential damages. The sole liability of the manufacturer under this warranty is limited to the replacement of defective product. Product damaged by improper use, accident, neglect, alteration, abuse or improper installation is excluded from this warranty.

RectorSeal® 2601 Spenwick Drive - Houston, TX 77055
ph: 713.263.8001 - 800.231.3345 fax: 713.263.7577 - 800.441.0051
www.rectorseal.com - Like Us on Facebook




Installation Instructions

Model No.

83113

(EZT113)

Important:
Install in strict accordance with RectorSeal Instructions as well as all applicable local plumbing, drainage and electrical codes.



Drain Pan Outlet ▶

Assembly Instructions

1. Dry fit, and mark components, rotating U-Bend (B) and Cross Tee (C) to required angles for installation.
2. Glue components (A thru C) using dry fit markings. Then glue assembly into Drain Pan Line
3. Glue Drain Line (E) into center leg of Outlet Tee (C). Drain Line must exit building with at least a 5° angle.
4. Check that Red Cap (D) are tightly secured.
5. Attach cleaning label as indicated.

Note: Insulation is required when trap is installed in unconditioned space where sweating can occur.