


Installation reference duct support system

Use the chart to check the length of Velcro strap required to make the installation. The drop is measured from the ceiling clip or beam to the centre line of the duct when installed. Refer diagram.

Measure to centre line
of duct at installed drop



All dimensions in mm

Duct Diameter	Drop 200	Drop 300	Drop 400	Drop 500	Drop 600	Drop 700	Drop 800	Drop 900	Drop 1000
150	700	890	1080	1280	1470	1670	1870	2070	2270
200	790	980	1170	1360	1560	1760	1960	2150	2350
250	900	1070	1260	1450	1650	1840	2040	2240	2440
300	1020	1170	1360	1540	1740	1930	2130	2320	2520
350	1140	1280	1460	1640	1830	2020	2220	2410	2610
400		1390	1560	1740	1920	2110	2300	2500	2700
450		1510	1650	1840	2020	2210	2400	2590	2790
500		1640	1740	1940	2120	2300	2490	2680	2870
550			1830	2050	2220	2400	2590	2770	2970
600			1920	2150	2320	2500	2680	2870	3060

Installation duct support

